

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20180801-E480621  
**Report Reference** E480621-20170228  
**Issue Date** 2018-AUGUST-01

**Issued to:** Novomet-Perm JSC  
395, Shosse Kosmonavtov  
614065 Perm, Permskii kray RUSSIAN FEDERATION

**This is to certify that representative samples of** INDUSTRIAL CONTROL PANELS  
Enclosures for Industrial Control Panels – cat. no. NVSD.

Ratings:  
UL Type Rating: 1, 3R  
Ambient Temperature: 50°C.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL 508A , Standard for Industrial Control Panels.  
Standards C22.2 No. 14–13, Industrial Control Equipment.

**Additional Information:** See the UL Online Certifications Directory at [www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

